



# Sanitary Sewer Overflow Annual Report

Division of Surface Water

**Date:** 2/5/2025  
**Facility name:** Wooster WPCP  
**Ohio NPDES permit no.:** 3PD00013-SD  
**Period covered by report:** 1/1/2024-12/31/2024

**Contact person**

**Name:** Chad Frank  
**Title:** Plant Supervisor  
**Mailing address:** 1123 Old Columbus Rd. Wooster, OH 44691  
**Telephone:** (330)263 - 5294  
**Email:** cfrank@woosteroh.com

**Certification:**

*I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.*

**Name** Chad Frank **Title:** Plant Supervisor  
**(typed):** \_\_\_\_\_

**Signature:**  **Date:** 2/5/2025







Enter narrative analysis of WIB patterns by location, frequency and cause.

During the 2024 calendar year there were no Sanitary Sewer Overflows "SSO".

There were 21 water in the basements "WIB" occurrences for the five sewer sheds of Wooster.

Seven were located in the Applecreek sewer shed. Issues with private laterals/sewers caused five. The remaining two were caused by roots, which were jetted/cut to restore flow. One of the lines clogged by roots is scheduled to be relined this year.

Four were located in the Bever sewer shed. Issues with private laterals caused all four.

Eight were in the Christmas Run sewer shed. Issues with private laterals caused four. Three were related to a heavy rain event that dumped two inches in two hours. After that, the lines in the area were televised, and no issues were found. The last event was caused by debris in a line. The manhole was flushed, and the main line jetted to restore flow.

Two were in the Elm sewer shed. Issues with private laterals caused both.

No issues were in the Killbuck sewer shed.

During the 2024 calendar year, our staff televised 53,695 feet of mains, exceeding our goal of 40,000 feet annually. They also jetted 56,515 feet of mains, exceeding our goal of 40,000 feet annually. We continually strive to maintain our sewerage system to avoid SSOs and WIB issues.