



Sanitary Sewer Overflow Annual Report

Division of Surface Water

Date: 2/1/24
Facility name: City of Wooster Water Recovery Facility
Ohio NPDES permit no.: 3PD00013*RD
Period covered by report: 2022

Contact person

Name: Chad Frank
Title: Plant Supervisor
Mailing address: 1123 Old Columbus Road, Wooster Ohio 44691
Telephone: (330)263 - 5294
Email: cfrank@woosteroh.com

Certification:

I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.

Name Chad Frank **Title:** Plant Supervisor

(typed): _____
Signature: 

Date: 2-1-24

SSO Annual Report Table 1: SSO Identification

Ohio NPDES Permit No.: 3PD00013*RD

| Identification No. ^A | Location Description | Receiving Water ^B | Eliminated ^C |
|---------------------------------|----------------------|------------------------------|-------------------------|
| 301 | Manhole ID #21,518 | Little Apple Creek | 1/23/23 |
| 302 | Walmart Lift Station | Little Apple Creek | 3/26/23 |
| 303 | Walmart Lift Station | Little Apple Creek | 8/5/23 |
| 304 | Manhole ID #21,240 | Little Apple Creek | 9/9/23 |
| 305 | Manhole ID #70,766 | None | 9/18/23 |
| 306 | Manhole ID #20,418 | None | 11/28/23 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

A. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.
 B. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)." If an SSO does not reach a receiving water, enter (None".
 C. If an SSO has been eliminated, enter the date of elimination (MM/DD/YY).

SSO Annual Report Table 2: SSO Event Information

Ohio NPDES Permit No.: 3PD00013*RD

| Date ^A | Identification No. ^B | Receiving Water ^C | Volume ^D |
|-------------------|---------------------------------|---|---------------------|
| 1/23/23 | 301 | Little Apple Creek | .028 |
| 3/26/23 | 302 | SS to Small Creek which flows to Little Apple Creek | .008 |
| 8/5/23 | 303 | SS to Small Creek which flows to Little Apple Creek | .0005 |
| 9/9/23 | 304 | Little Apple Creek | .044 |
| 9/18/23 | 305 | None | .0006 |
| 11/28/23 | 306 | None | .0012 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

- A. Enter date as "MM/DD/YY". Enter "Various" to summarize overflows of less than 1000 gallons from an SSO location
- B. Enter the unique identification assigned in Table 1.
- C. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)." If an SSO does not reach a receiving water, enter "None".
- D. Enter estimate of volume in MG (million gallons). Enter estimate of total volume if summarizing data.

Use additional pages as needed.

SSO Annual Report Table 3: Water in Basement Occurrences

Ohio NPDES Permit No.: 3PD00013*RD

| Sewershed ^A | WIB Occurrences ^B | Causes ^C |
|--------------------------|------------------------------|----------------------------|
| Little Apple Creek | 3 | R, B |
| Christmas Run | 1 | R |
| Elm | 3 | L |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| Total Occurrences | 7 | L (3), R (2), B (1) |

- A. A sewershed is a specific geographic area, such as a city block or a subdivision, that drains to a common outlet.
- B. Enter the total number of water in basement occurrences report for the sewershed.
- C. Enter all causes that apply: W = extreme weather; E = equipment failure; P = power failure; D = debris in line; R = roots; G = grease; B = other blockages; L = Line deterioration; V = vandalism; O = other, prove details.

Use additional pages as needed.

Enter narrative analysis of WIB patterns by location, frequency and cause.

For the 2023 year there were seven WIB occurrences

Elm service area had three occurrences, all involving issues with the homeowners laterals.

Christmas Run service area had one issue caused by roots in the main line. The area of the blockage is on a three year rotation to be root treated.

Little Applecreek service area contained the remaining three issues. Two of the issues were caused by roots in the main line, one of which has been added the next lining project, the other will be monitored for future issues. The remaining issue was caused by grease blockage. The pretreatment coordinator will spot check grease traps in the area to ensure they are abiding by the citys Codified Ordinance 923.04(k)-1 in regards to cleaning and maintenance.