



Sanitary Sewer Overflow Annual Report

Division of Surface Water

Date: 1/13/2021
Facility name: City of Wooster Water Resource Recovery Facility
Ohio NPDES permit no.: 3PD00013*RD
Period covered by report: 1/1/2020-12/31/2020


Contact person

Name: Steven S. Carathers
Title: Supervisor
Mailing address: 1123 Old Columbus Rd. Wooster, Ohio 44691
Telephone: (330)263 - 5294
Email: scarathers@woosteroh.com

Certification:

I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.

Name Steven S. Carathers Title: Supervisor
(typed):

Signature:  Date: 1-13-2021

SSO Annual Report Table 1: SSO Identification		Ohio NPDES Permit No.: 3PD00013*RD	
Identification No. ^A	Location Description	Receiving Water ^B	Eliminated ^C
301	427 Maple St.	Little Applecreek	8/19/2020

- A. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.
- B. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)." If an SSO does not reach a receiving water, enter (None".
- C. If an SSO has been eliminated, enter the date of elimination (MM/DD/YY).

Use additional pages as needed.
EPA 4238 (Rev. 6/14)

Sewershed ^A	WIB Occurrences ^B	Causes ^C
Bever	2	D,R
Elm	0	
Little Applecreek	3	R
Christmas Run	7	L, R,D
Total Occurrences	7	

A. A sewershed is a specific geographic area, such as a city block or a subdivision, that drains to a common outlet.
 B. Enter the total number of water in basement occurrences report for the sewershed.
 C. Enter all causes that apply: W = extreme weather; E = equipment failure; P = power failure; D = debris in line; R = roots; G = grease; B = other blockages; L = Line deterioration; V = vandalism; O = other, prove details.

Use additional pages as needed.

Enter narrative analysis of WIB patterns by location, frequency and cause.

Christmas Run had the most WIB at 7, the biggest issues were roots in the homeowner lateral or main
Little Applecreek was the next with 3, main issue was roots in home owners lateral
Bever had 2 due to roots