

CITY OF WOOSTER
Sodium Hypochlorite

ADDENDUM NO. 1
December 7, 2023

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification. The following change is being made as described herein:

I. CLARIFICATION

1. The product furnished shall meet the requirements of NSF Standard 60 for drinking water.

Please acknowledge receipt of this addendum by indicating the Addendum No. and date on the Bid.

CITY OF WOOSTER
DIVISION OF ENGINEERING



John Rice, P.E.
City Engineer