

**CITY OF WOOSTER  
WATER RESOURCE RECOVERY FACILITY  
VERTICAL LOOP REACTOR (VLR) 1 AND 2 IMPROVEMENTS  
CONTRACT B**

ADDENDUM NO. 1  
December 6, 2023

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification. Modifications are being made as described in the Addendum 1 that follows, as prepared by Jones & Henry Engineers, Ltd.

*Please acknowledge receipt of this addendum by inserting any revised pages into the contract documents and by indicating the Addendum No. and date on the Bid.*

**CITY OF WOOSTER  
DIVISION OF ENGINEERING**



John Rice, P.E.  
City Engineer



---

City of Wooster, Ohio

Water Resource Recovery Facility Vertical Loop Reactor (VLR) 1 and 2  
Improvements  
Contract B

---

**ADDENDUM 1**

---

December 6, 2023

Plan holders on the City of Wooster, Ohio; Water Resource Recovery Facility, Vertical Loop Reactor (VLR) 1 and 2 Improvements, Contract B are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

**SPECIFICATIONS**

Page 11106 – 6 paragraph 1.05 B. 1. Under the Supplies change the number “636” to “318”

Page 11128-2 paragraph 2.01 Add the following new paragraph D

“D. The blower shall be an Aerzen hybrid screw D98S with a 150-horsepower motor matching the previous blowers at the plant.

Page 11128-5 paragraph 2.05 A. 7.

Delete the words “an exterior source” and replace with “the existing air plenum”

Attachments:     None

**RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED IN THE PROPOSAL.**